

CERTIFICATE OF CONFORMITY

This product Certificate is issued under Section 269 of the Building Act 2004 for:

Jet Stream® MAX and Supafil Cavity Insulation



Page 1 of 3

Product Description

Jet Stream MAX and Supafil Cavity Insulation Systems are non-bonded, granulated glasswool fibre materials blown on-site in loose form to a nominal density of 25-28 kg/m³

Product purpose and use

Jet Stream MAX and Supafil Cavity Insulation Systems have been assessed for use as a thermal insulation material for new buildings within the following scope:

- Walls when installed in the cavities between framing members
- Floors when installed in the cavities between flooring members
- Skillion roofs when installed in the cavities between roofing members.

Certificate holder

Knauf Insulation Pty Ltd
Unit 2, 44 Borthwick Avenue, Murarrie, QLD, 4172, Web: www.knaufinsulation.com.au , Tel: +61 7 3393 7300

Compliance with the New Zealand Building Code (NZBC):


Clause B2 DURABILITY: Performance B2.3.1(a) not less than 50 years, and B2.3.2(a). Jet Stream MAX and Supafil Cavity Insulation Systems will meet these requirements.

Clause C3 PROTECTION FROM FIRE: Performance C3.7(a). Jet Stream MAX and Supafil Cavity Insulation Systems will contribute to meeting these requirements.

Clause E3 INTERNAL MOISTURE: Performance E3.3.1. Jet Stream MAX and Supafil Cavity Insulation Systems will contribute to meeting this requirement.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. Jet Stream MAX and Supafil Cavity Insulation Systems will meet this requirement and will not present a health hazard to people.

Clause H1 ENERGY EFFICIENCY: Performance H1.3.1(a) and H1.3.2 E. Jet Stream MAX and Supafil Cavity Insulation Systems will contribute to meeting these requirements.

CodeMark Certification Body		19/7/2016	18/07/2019	18/07/2022	GM-CM30067-RevB
Global-Mark Pty Ltd, Suite 4.07, 32 Delhi Road, North Ryde NSW 2113, Australia Tel: +61 (0)2 9886 0222 www.Global-Mark.com.au	Herve Michoux Managing Director	Date of issue	Last update	Date of next re-certification	Certificate Number

The purpose of construction site audits is to confirm the practicability of installing the product; and to confirm the appropriateness and accuracy of installation instructions. In issuing this certificate, Global-Mark has relied on the independent expert and/or laboratory advise or reports. This certificate is issued by Global-Mark Pty Limited, an independent certification body accredited by the product certification accreditation body (JAS-ANZ) appointed by the Chief Executive of the Ministry of Business Innovation and Employment under the Building Act 2004. The Ministry of Business Innovation and Employment does not in any way warrant, guarantee, or represent that the building method or product the subject of this certificate conforms with the New Zealand Building Code, nor accept any liability arising out of the use of the building method or product. The Ministry of Business Innovation and Employment disclaims, to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages, and costs arising as a result of the use of the building method(s) or product(s) referred to in this certificate. This Certificate may only be reproduced in its entirety.

It is advised to check that this Certificate of Conformity is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the Ministry of Business Innovation and Employment website, <http://www.mbie.govt.nz/>

New Zealand Building Code (NZBC) references the Building Code in force at the time of issuing the product certificate.

Certificate holder will notify Global-Mark Pty Ltd in accordance with Regulation 15 of the Building (Product Certification) Regulations 2008

CERTIFICATE OF CONFORMITY

This product Certificate is issued under Section 269 of the Building Act 2004 for:

Jet Stream® MAX and Supafil Cavity Insulation



Page 2 of 3



Subject to the following conditions and limitations:

1. Product specification and incorporation of Jet Stream MAX and Supafil Cavity Insulation Systems into the building design shall be carried out by a designer / architect / engineer or a building professional who:
 - Is qualified to design the buildings covered under the 'Scope' of use of this product.
 - Has ready access to the technical specifications including the manufacturer publications and standards referenced in this certificate. .
2. Specification of the product shall be in accordance with the following Knauf publications:
 - Supafil – Blow-in Glasswool Insulation Datasheet, December 2015, Ref.: KIAN1215315DS.
 - Jet Stream MAX – Blow-in Glasswool Insulation Datasheet, June 2018, Ref.: KIAN0814093DS.
3. Installation shall be carried out by a Knauf Insulation accredited installer in accordance with Knauf Application Guidelines – Walls, Floors and Skillion Roofs, December 2015, Ref.: KIAN0815225BR, to meet the stated thermal performance rating of the insulation, and NZS 4246:2016.
4. In wall applications the product has a thermal conductivity of 0.032 W/mK at a minimum density of 28 kg/m³ and resistance (R-value) as specified in Table 1, which contributes to the overall thermal resistance value of wall construction. The designer is responsible for determining the total thermal resistance (R_T) of the wall and its contribution to the overall energy efficiency of the building into which the insulation is installed.

Table 1: Jet Stream MAX and Supafil Cavity Insulation Systems R-value in Relation to Thickness - Walls

Nominal Thickness (mm)	R-value (m ² .°C/W)
70	2.1
75	2.3
90	2.8
100	3.1
140	4.3

5. In skillion roof and floor applications the product has a thermal conductivity of 0.038 W/mK at a minimum density of 25 kg/m³ and resistance (R-value) as specified in Table 2, which contributes to the overall thermal resistance value of the skillion roof or floor construction. The designer is responsible for determining the total thermal resistance (R_T) of the skillion roof or floor and their contribution to the overall energy efficiency of the building into which the insulation is installed.

Table 2: Jet Stream MAX and Supafil Cavity Insulation Systems R-value in Relation to Thickness - Floors and Skillion Roofs

Nominal Thickness (mm)	R-value (m ² .°C/W)
50	1.3
90	2.3
100	2.6
140	3.6
190	5.0
240	6.3

6. The requirements of AS/NZS 4859.1:2002 (incorporating Amendment No.1) and NZS 4246:2016 must be maintained.
7. Installation shall be carried out only after the building is weatherproof, and after the materials within the building have dried to

CERTIFICATE OF CONFORMITY

This product Certificate is issued under Section 269 of the Building Act 2004 for:

Jet Stream® MAX and Supafil Cavity Insulation



Page 3 of 3



a sufficient degree that moisture is not transported into the insulation material and in accordance with the requirements of NZBC Acceptable Solution E2/AS1 Paragraph 10.2 (a), or the moisture content as required by the lining manufacturer.

8. Separation or protection must be provided to Jet Stream® MAX from heat sources such as fire places, heating appliances, flues, chimneys and downlights. Refer to Part 7 of NZBC Acceptable Solutions C/AS1 - C/AS6 and NZBC Verification Method C/VM1.
9. Insulation that has become damp must be removed and the cause of the dampness repaired. The cavity must be clean and dry before fitting new insulation of an equivalent thermal rating.
10. Knauf Insulation Pty Ltd Approved Installers are responsible for the handling and storage which must be completed in accordance with the Jet Stream MAX and Supafil Cavity Insulation Systems procedure documents.
11. Jet Stream MAX and Supafil Cavity Insulation Systems must be stored under cover and in dry conditions.
12. Jet Stream MAX and Supafil Cavity Insulation Systems are non-combustible. Compliance with C3.7(a) will be achieved under the condition that all other building element of the walls are also non-combustible.

End of the document